

Water Testing Laboratory P.H.E Sub Division

Gandhi Nagar Jammu

No: PHE/SD/WTL/GIN/128

S.No	Sample Details	
1	Location & address of the sampling Point	International Public School
2	Name of the District	Jammu
3	Name of block	Satwari
4	Panchayat and Municipal area	Satwari
5	Date of testing	5 July 2020
6	Sample given by person (authorise/unauthorised)	Mr. Sidhart Singh (International Public School)

S.no	Water quality parameters	Units	Results
1.	Colour	Hazen	Colorless
2.	Odor	OK
3.	Turbidity	NTU	0
4.	PH		6.5
5.	T.D.S	Ppm	225
6.	Calcium	Mg/lit	90
7.	Chloridedo.....	-
8.	Fluoridedo.....	0.5
9.	Irondo.....	0.05
10.	Ammoniado.....	-
11.	Residual Chlorinedo.....	-
12.	Total hardnessdo.....	200
13.	Total Alkalinitydo.....	200
14.	Nitratedo.....	5
15.	Aluminiumdo.....	-
16.	Phosphatedo.....	0.20
17.	Copperdo.....	-
18.	Magnesiumdo.....	26.73
19.	Coil forms presencedo.....	0
20.	Manganesedo.....	-
21.	Arsenic	- do -	0

Remarks :- The water is potable.
All the above parameters checked for the given water sample are within the BIS permissible limit.

Water Testing Authority

(Chemist)

Copy to the:-

- Copy to the Assistant Executive Engineer P.H.E Sub Division Gandhi Nagar Jammu for information and transmission to the concerned authorities please.